

HDPE SOCKET FUSION

Pipes & Fittings



We are the SOLUTIONS
to your fusion joints.

Polyware[®]
PE PIPELINE SYSTEM SOLUTIONS PROVIDER

01



PE100 HDPE Pipe

Outside Diameter (OD) (mm)
Size

Straight

5.8m / length PN16 (SDR 11) *20, 25, 32, 40, 50, 63, 75, 90, 110

50m Coil

PN16 (SDR 11) 75, 90, 110

100m Coil

PN16 (SDR 11) *20, 25, 32, 40, 50, 63

*20 : PN20 / SDR9

Reducer

Normal Diameter (mm)
Size

25 x 20	40 x 20	50 x 20	63 x 20	75 x 50	90 x 50	110 x 50
32 x 20	40 x 25	50 x 25	63 x 25	75 x 63	90 x 63	110 x 63
32 x 25	40 x 32	50 x 32	63 x 32		90 x 75	110 x 75
		50 x 40	63 x 40			110 x 90
			63 x 50			



Socket

Normal Diameter (mm)
Size

20	40	75
25	50	90
32	63	110



Equal Elbow 90°

Normal Diameter (mm)
Size

20	40	75
25	50	90
32	63	110



Elbow 45°

Normal Diameter (mm)
Size

20	40	75
25	50	90
32	63	110



Equal Tee

Normal Diameter (mm)
Size

20 x 20 x 20	40 x 40 x 40	75 x 75 x 75
25 x 25 x 25	50 x 50 x 50	90 x 90 x 90
32 x 32 x 32	63 x 63 x 63	110 x 110 x 110



02



Reducing Tee

Normal Diameter (mm)
Size

25 x 20	50 x 20	63 x 20	75 x 50	110 x 50
32 x 20	50 x 25	63 x 25	75 x 63	110 x 63
32 x 25	50 x 32	63 x 32	90 x 50	110 x 75
40 x 20	50 x 40	63 x 40	90 x 63	110 x 90
40 x 25		63 x 50	90 x 75	
40 x 32				



Female Threaded Adaptor

Normal Diameter (mm)
Size

20 x 1/2"	32 x 1/2"	40 x 1 1/4"	50 x 1 1/4"	75 x 2"
20 x 3/4"	32 x 3/4"	40 x 1 1/2"	50 x 1 1/2"	75 x 2 1/2"
25 x 1/2"	32 x 1"	40 x 1"	50 x 2"	90 x 3"
25 x 3/4"			63 x 1 1/2"	110 x 3"
			63 x 2"	110 x 4"



Male Threaded Adaptor

Normal Diameter (mm)
Size

20 x 1/2"	32 x 1/2"	40 x 1 1/4"	50 x 1 1/4"	63 x 1 1/2"	90 x 3"
20 x 3/4"	32 x 3/4"	40 x 1 1/2"	50 x 1 1/2"	63 x 2"	110 x 3"
25 x 1/2"	32 x 1"	40 x 1"	50 x 2"	75 x 2"	110 x 4"
25 x 3/4"				75 x 2 1/2"	



Female Elbow

Normal Diameter (mm)
Size

20 x 1/2"	32 x 1/2"	40 x 1"	50 x 1 1/4"	63 x 1 1/2"	90 x 3"
20 x 3/4"	32 x 3/4"	40 x 1 1/4"	50 x 1 1/2"	63 x 2"	110 x 3"
25 x 1/2"	32 x 1"	40 x 1 1/2"	50 x 2"	75 x 2"	110 x 4"
25 x 3/4"				75 x 2 1/2"	



Male Elbow

Normal Diameter (mm)
Size

20 x 1/2"	32 x 3/4"	50 x 1 1/4"	75 x 2"
20 x 3/4"	32 x 1"	50 x 1 1/2"	75 x 2 1/2"
25 x 1/2"	40 x 1"	50 x 2"	90 x 3"
25 x 3/4"	40 x 1 1/4"	63 x 1 1/2"	110 x 3"
32 x 1/2"	40 x 1 1/2"	63 x 2"	110 x 4"



Stiffener

Normal Diameter (mm)
Size

20 PN16
25 PN16
32 PN16

03



Reducing Elbow

Normal Diameter (mm)
Size

25 x 20
32 x 20
32 x 25
40 x 32
50 x 40
63 x 50



Female Tee

Normal Diameter (mm)
Size

20 x 1/2"	32 x 1/2"	50 x 1 1/4"	75 x 2"
20 x 3/4"	32 x 3/4"	50 x 1 1/2"	75 x 2 1/2"
25 x 1/2"	32 x 1"	50 x 2"	90 x 3"
25 x 3/4"	40 x 1"	63 x 1 1/2"	110 x 3"
	40 x 1 1/4"	63 x 2"	110 x 4"
	40 x 1 1/2"		



Male Tee

Normal Diameter (mm)
Size

20 x 1/2"	32 x 1/2"	50 x 1 1/4"	75 x 2"
20 x 3/4"	32 x 3/4"	50 x 1 1/2"	75 x 2 1/2"
25 x 1/2"	32 x 1"	50 x 2"	90 x 3"
25 x 3/4"	40 x 1"	63 x 1 1/2"	110 x 3"
	40 x 1 1/4"	63 x 2"	110 x 4"
	40 x 1 1/2"		



End Cap

Normal Diameter (mm)
Size

20	40	75
25	50	90
32	63	110



Flange Adapter

Normal Diameter (mm)
Size

20	40	75
25	50	90
32	63	110



Stopcock

Normal Diameter (mm)
Size

20	32	50
25	40	63

HÜRNER Socket Welder HMS

Product Description	Size (mm)
HURNER Socket Welder HMS	20 - 63 20 - 125



 Made in Germany

HÜRNER Spigot & Socket

Product Description	Size (mm)
HURNER Spigot & Socket	20, 25, 32, 40, 50, 63, 75, 90, 110



Installation Method

1 Preparation



Choose the appropriate heating bushes and turn on the HURNER Socket Welder.

2 Cutting the pipe



Use a pipe cutter to cut at an angle of 90° to a given line.

3 Cleaning the pipe



Wipe the inside & outside of the fitting and pipe to make sure they are cleaned.

Please don't touch the cleaned surface with your hand/s.

4 Fusion depth measuring



Mark the insertion depth with a marker. Kindly refer to the table (Socket Fusion Welding Parameters) below.

5 Heating Time



Place the pipe and fitting into the socket horizontally.

6 Fusing and cooling time



Push both the pipe ends to fit properly within the desired time frame, as per table (Socket Fusion Welding Parameters) below.

Please do not twist.
Do not re-use a melted fitting. Please start over from Step 1 if the melted pipe is not complete.

Socket Fusion Welding Parameters

OD (mm)	Insertion Depth (mm)	Heating Time (sec)	Fusion Time (sec)	Cooling Time (min)
20	14.0	5	4	2
25	15.0	7	4	2
32	16.5	8	6	4
40	18.0	12	6	4
50	20.0	18	6	4
63	23.0	24	8	6
75	27.5	30	8	8
90	32.0	40	8	8
110	38.0	50	10	8



Please scan QR code for our product installation.

Socket fusion welding is a commonly used method for assembling plastic pipeline systems using injection moulded fittings. It is mainly applied to pipe fitting diameters of ½" (20mm) up to 4" (110mm).

The operating concepts are simple, with the binding cycle primarily made up of a heating phase and a cooling or welding phase. It is socket fused by putting heat to pre-arranged pipe ends, then plunging the pipe ends together with a preset force to make a constant socket fusion joint.

POLYFUSE PE SOCKET FUSION

POLYFUSE PE pipes strictly conform to MS1058: Part 2: 2005 standard specifications. Our products are licensed by SIRIM and approved by local water authorities to be used as the top mark for quality. The granting of the top mark confirms that our company's manufacturing, testing and quality control systems comply with the stringent licensing requirements and thus ensures that our products quality is consistently maintained.

Advantages for using POLYFUSE HDPE Pipe

Our pipes are SIRIM approved and manufactured using approved raw materials, high density polyethylene and comply to MS 1058.

- Ease, reliability and cost efficiency of jointing and laying operations.
- Non toxic, low abrasion and flexibility.
- Excellent resistance to water hammer phenomena.
- Absence of scale on inside walls results in consistency of pipeline hydraulic performance.
- Immune to corrosion phenomena and have very good resistance to a wide range of chemicals.



CERTIFICATE OF CONFORMITY

This certificate hereby certifies that the product as detailed in this certificate has satisfactorily complied with the requirements of the appropriate Standard(s) and the Certification Scheme Requirement of WATERMARKS CERTIFICATION (MALAYSIA) SDN. BHD.

Name and Address of Certificate Holder
 POLYWARE SDN. BHD.
 PT 285794, PERSIARAN PERINDUSTRIAN PENGKALAN 16,
 KAWASAN PERINDUSTRIAN PENGKALAN,
 31500 IPOH, PERAK, Malaysia

Scope of Certification
 Name of Scheme
 PRODUCT CERTIFICATION SCHEME

Product Name	Product Standard(s)
POLYETHYLENE (PE) FITTINGS FOR WATER SUPPLY AND FOR DRAINAGE AND SEWERS UNDER PRESSURE	BS EN 12201-3: 2011 + A1: 2012

Product Descriptions
 (refer to SCHEDULE)

Brand Name
 POLYFUSE

Name and Address of Manufacturer
 POLYWARE SDN. BHD.
 PT 285794, PERSIARAN PERINDUSTRIAN PENGKALAN 16,
 KAWASAN PERINDUSTRIAN PENGKALAN,
 31500 IPOH, PERAK, Malaysia

Certification Number	Initial Certification
WCM PC 000776	07 APRIL 2026

Certificate Validity
 06 APRIL 2027

This certificate is awarded on the basis of an assessment against the standard(s) for conformity which includes the manufacturer's production control system, production facilities, product conformity to standard coupled with assessment of the supporting quality management system. This Certificate remains the property of WCM and shall be returned upon request. The use of this certificate is subject to the terms and conditions of the Certification Agreement. This certificate is remains valid subject to satisfactory yearly surveillance assessment.

Issued by
 **Ts. MOHD SHAHREZAL BIN MOHD ISMAIL**
 Managing Director
 WATERMARKS CERTIFICATION (MALAYSIA) SDN. BHD.
 LOT NO. 1, TINGKAT 6, WISMA PPRS,
 PERSIARAN PERINDUSTRIAN PENGKALAN,
 31500 IPOH, PERAK, MALAYSIA
 TEL: 05-6524 1666
 FAX: 05-6524 1668
 www.watermarking.com.my

Product Standard(s): BS EN 12201-3: 2011 + A1: 2012



CERTIFICATE OF CONFORMITY

This certificate hereby certifies that the product as detailed in this certificate has satisfactorily complied with the requirements of the appropriate Standard(s) and the Certification Scheme Requirement of WATERMARKS CERTIFICATION (MALAYSIA) SDN. BHD.

Name and Address of Certificate Holder
 POLYWARE SDN. BHD.
 PT 285794, PERSIARAN PERINDUSTRIAN PENGKALAN 16,
 KAWASAN PERINDUSTRIAN PENGKALAN,
 31500 IPOH, PERAK, Malaysia

Scope of Certification
 Name of Scheme
 PRODUCT CERTIFICATION SCHEME

Product Name	Product Standard(s)
POLYETHYLENE (PE) FITTINGS FOR WATER SUPPLY AND FOR DRAINAGE AND SEWERS UNDER PRESSURE	MS 1058-3: 2023

Product Descriptions
 (refer to SCHEDULE)

Brand Name
 POLYFUSE

Name and Address of Manufacturer
 POLYWARE SDN. BHD.
 PT 285794, PERSIARAN PERINDUSTRIAN PENGKALAN 16,
 KAWASAN PERINDUSTRIAN PENGKALAN,
 31500 IPOH, PERAK, Malaysia

Certification Number	Initial Certification
WCM PC 000777	07 APRIL 2026

Certificate Validity
 06 APRIL 2027

This certificate is awarded on the basis of an assessment against the standard(s) for conformity which includes the manufacturer's production control system, production facilities, product conformity to standard coupled with assessment of the supporting quality management system. This Certificate remains the property of WCM and shall be returned upon request. The use of this certificate is subject to the terms and conditions of the Certification Agreement. This certificate is remains valid subject to satisfactory yearly surveillance assessment.

Issued by
 **Ts. MOHD SHAHREZAL BIN MOHD ISMAIL**
 Managing Director
 WATERMARKS CERTIFICATION (MALAYSIA) SDN. BHD.
 LOT NO. 1, TINGKAT 6, WISMA PPRS,
 PERSIARAN PERINDUSTRIAN PENGKALAN,
 31500 IPOH, PERAK, MALAYSIA
 TEL: 05-6524 1666
 FAX: 05-6524 1668
 www.watermarking.com.my

Product Standard(s): MS 1058-3: 2023